#### Features

Recordable voltage, current, last 4 faults, KWh usage, and power factor is available when using communications package.

Digitally programmable for precise customizing.

Sixteen set points can be programmed for maximum protection.

Last fault memory provides instant troubleshooting diagnostics.

UL and cUL listed as an overload relay.

RS485 communication port for use with computerized systems using Modbus protocol.

# Applications

The Model 777 can be used on any 3-phase motor drawing 2-800 amps. Applications include CONVEYOR SYSTEMS, HVAC EQUIPMENT, PUMPS, SAWS, GRINDERS AND OTHER 3-PHASE ELECTRIC MOTORS.

# Description

The Model 777 is a fully-programmable electronic overload relay. An alphanumeric LED display provides programming and diagnostic information. Sixteen parameters can be programmed in the Model 777:

- 1) Low Voltage Setpoint
- 2) High Voltage Setpoint
- 3) Voltage Unbalance Setpoint
- 4) CT Size/Loop Setting
- 5) Overcurrent Trip Point
- 12) No. of restarts after an overload (Manual or Automatic) 13) RS485 Address

9) Rapid-Cycle Timer (RD1)

10) Fault Restart Delay (RD2 - Motor Cool-down Timer)

11) Underload Restart Delay (RD3 - Dry Well Recovery Timer)

- 6) Undercurrent Trip Point
  - 14) No. of restarts after an underload fault
- 7) Current Unbalance Trip Point 15) Underload Trip Delay
- 8) Trip Class (5, 10, 15, 20, 30) 16) Ground Fault Trip Point

Programming the Model 777 is an easy four step process: 1) Rotate the MODE SELECT switch to the parameter to be programmed; 2) Depress and hold the RESET/PROGRAM button; 3) Rotate the DISPLAY/PROGRAM dial to the desired setting as shown in the LED display; and 4) Release the RESET/PROGRAM button.

An RS-485 port allows the Model 777 to be connected to an RM-1000 or RM-2000 remote monitor or directly to a computer or PLC. The RM-2000/777 motor management system combines unsurpassed electronic motor protection and critical, user friendly motor monitoring. SymCom's Solutions Software (sold separately) can be used to monitor and control up to 99 Model 777s from a central computer. Using Solutions Software, an operator can control motors, view the operating parameters, and record the following operating parameters:

- Line Line Voltages (Recordable)
- Line Currents (Recordable)
- Last 4 Faults (Recordable)
- Restart Delay Timers • KWH Usage (Recordable)
- Power Factor (Recordable)





Model 777 Model 777-LR Model 777-575

> **Overload Relays** Engineered Protection

## **Protects 3-Phase** motors from:

- Overload
- Underload
- Jams
- Undervoltage
- •Overvoltage
- •Single phasing
- •Unbalance
  - (voltage & current)
- •Ground fault (Class II)
- Rapid cycling
- Phase reversal

## Standard Features

- •Fully programmable
- •UL and cUL listed
- •CE compliant
- •CSA approved
- Automatic or manual reset
- •Tamper guard
- •RS485 communications port
- •Surface mount or
- **DIN** rail mount
- Alphanumeric LED diagnostic display
- Last fault memory
- 5 year warranty
- Made in USA

# New Features

- Network programmable
- •Ability to clear last fault



Þ

Wiring Diagrams • Charts

TYPICAL WIRING DIAGRAM FOR MODEL 777 (20 TO 90 AMPS)



# Wiring configuration based on motor amps.

Model	Full Load Amps	# of Loops	# of Conductors through A, B and C	MULT to Program (CT Ratio)
777-LR	1 - 2 2 - 9	1 0	2 1	2 1
777	8 - 12 12 - 25 25 - 90	2 1 0	3 2 1	3 2 1
External CTs required. See wiring diagram for external CTs	80 - 110 110 - 160 160 - 220 220 - 320 320 - 420 400 - 520 480 - 600 560 - 800	4 4 4 4 4 4 4	5 5 5 5 5 5 5 5 5 5 5 5 5	100 (100:5) 150 (150:5) 200 (200:5) 300 (300:5) 400 (400:5) 500 (500:5) 600 (600:5) 800 (800:5)

SynCominc Motor Protection & Controls Since 1974 CURRENT TRANSFORMER WIRING DIAGRAM FOR MODEL 777 (80 TO 800 AMPS)



## **Overload Trip Classes**





Þ

Accessories • Dimensions

# RS485MS-2W

The optional RS485MS-2W communications module is required if Model 777-type products are used on a Modbus network or with RM-1000 or RM-2000 remote displays. The communications module provides RS-485 bus drive capabilities and optical isolation from the overload electronics and powerline.

# RM-1000

The RM-1000 is a local display/controller with RS-485 Modbus network capabilities. Its modular design allows for flexible, inexpensive installation yet provides robust motor management. Plant personnel safety is also enhanced by allowing system troubleshooting and control without opening the starter box.



777 • 777-LR • 777-575

**Overload Relays** 



# RM-2000

The RM-2000 motor monitoring device used in conjunction with SymCom's Model 777 provides a complete motor management system. This system provides full electronic motor protection, historical data and critical, user-friendly motor-monitoring information. The RM-2000 also features a real-time clock, 2x20 backlit LCD, one upstream RS-485 Modbus communication port and is rated NEMA-3R when mounted on a panel door.

## 777 Manual Remote Reset Kit

The manual remote reset allows the 777 line of MotorSaver<sup>®</sup> and PumpSaver<sup>®</sup> products to be manually reset without opening the panel door. Simply connect the 9-pin adapter to the 777 communication port and mount the reset switch in a convenient location.



**777 Angle Mounting Bracket** 777 Angle Mounting Bracket allows the 777 line of MotorSaver<sup>®</sup> and PumpSaver<sup>®</sup> products to be mounted into shallow panels such as the Furnas Size 1 and other low profile panels. The angle bracket reduces the installed depth from 5.05" to 4.25".

# **Dimensions for All 777 Units**









Electrical

Specifications Model 777, Model 777-LR & Model 777-575

Input Voltage	200-480 VAC, 3Ø(Standard)	
	500-600VAC for model 777-575	
Frequency	50-60 Hz	
777 777-575	777-I P 777-575-I P	
2-25 Amps 30 (Loops Required)	1-45  Amps - 30(1  cons Required)	
25-90 Amps, 30 (Direct)	2-9 Amps, $30$ (Direct)	
80-800 Amps, 30(External CTs)		
Short Circuit Rating	10kA	
Power Consumption	10W (Maximum)	
Output Contact Rating SPDT (Form C)	Pilot duty rating: 480 VA @ 240 VAC	
	General purpose: 10A @ 240 VAC	
Expected Life		
Mechanical	1 x 10 <sup>6</sup> operations	
Electrical	1 x 10 <sup>5</sup> operations at rated load	
Accuracy at 25° C (77° F)		
Voltage	±1%	
Current	±3%(<100 Amps Direct)	
GF Current	±15%	
l iming	5% ± 1 second	
Voltage	+ 0.5% of nominal voltage	
Current	± 0.5% of horminal voltage	
Trip Times (Those not shown have user selectable trip times )		
Ground Fault Trip Time	Trip time	
101%-200% of Setpoint	8 seconds ± 1 second	
201%-300% of Setpoint	$4 \text{ seconds} \pm 1 \text{ second}$	
301%-400% of Setpoint	3 seconds ± 1 second	
401% or Greater	2 seconds ± 1 second	
Current Unbalance Trip Times		
% Over Setpoint Trip time	% Over Setpoint Trip time	
1% 30 seconds	5% 6 seconds	
2% 15 seconds	6% 5 seconds	
3% 10 seconds	10% 3 seconds	
4% 7.5 seconds	15% 2 seconds	
Safety Marks		
CE	IEC 60947-1, IEC 60947-5-1	
CSA Standarda Bassad		
Electrostatic Discharge (ESD)	IEC 1000-4-2 Level 3. 6by contact. 8by air	
Radio Frequency Immunity (REI), Conducted	IEC 1000-4-6. Level 3 10V/m	
Radio Frequency Immunity (RFI), Radiated	IEC 1000-4-3. Level 3 10V/m	
Fast Transient Burst	IEC 1000-4-4, Level 3, 3.5 kv input power	
Surge		
IEC	1000-4-5	
	Level 3, 2kv line-to-line; Level 4, 4kv line-to-ground	
ANSI/IEEE	C62.41 Surge and Ring Wave Compliance to a level of 6kv line-to-line	
Hi-potential Test	Meets UL508 (2 x rated V +1000V for 1 minute)	
Vibration	IEC 68-2-6, 10-55Hz, 1mm peak-to-peak, 2 hours, 3 axis	
Shock	IEC 68-2-27, 30g, 3 axis, 11ms duration, half-sine pulse	
Mechanical		
Dimensions	3.1"H x 5.1"D x 3.9"W	
Finderway Material	7 inch•lb	
Enclosure Material Weight	Polycarbonate	
Maximum Conductor Size Through 777	0.65" with insulation	
Maximum conductor Size Through 777		
Temperature Range	Ambient Operating: $-20^\circ - 70^\circ C (-4^\circ - 158^\circ E)$	
i sinperature nange	Ambient Storage: -40° - 80° C (-40° - 176° F)	
Pollution Degree	3	
Class of Protection	IP20, NEMA 1	
Relative Humidity	10-95%, non-condensing per IEC 68-2-3	
Programmable Operating Points	Range	
LV- Low Voltage Threshold	170V (450V*) - HV Setting	
HV- High Voltage Threshold	LV Setting - 528V (660V*)	
VUB- Voltage Unbalance Threshold	2 - 15% or 999	
MULT- # of Conductors or CT Ratio (XXX:5)	1-10 Conductors or 100-800 Ratio	
OC- Overcurrent Threshold	(20 to 100A) ÷ MULT or 80 to 120% of CT Primary; LR, (2 to 10A) ÷ MULT	
UC- Undercurrent Threshold	(0, 10 to 98A) + MULT or 40 to 100% of CT Primary; LR. (0, 1 to 9.8A) + MULT	
CUB- Current Unbalance Threshold	2 - 25% or 999	
TC Overeingent Trip Class ##	5, J5, 10, J10, 15, J15, 20, J20, 30, J30	
IC- Overcurrent Trip Class **	0, 2 - 500 Seconds	
RD1- Rapid Cycle Timer	0, 2 - 500 Seconds	
RD1- Rapid Cycle Timer RD2- Restart Delay After All Faults Except Undercurrent	0, 2 - 500 Seconds 2 - 500 Minutes	
RD1- Rapid Cycle Timer RD2- Restart Delay After All Faults Except Undercurrent (motor cool down timer) RD3- Restart Delay After Undercurrent	0, 2 - 500 Seconds 2 - 500 Minutes 2 - 500 Minutes	
RD1- Rapid Cycle Timer RD2- Restart Delay After All Faults Except Undercurrent (motor cool down timer) RD3- Restart Delay After Undercurrent (dry well recovery: timer)	0, 2 - 500 Seconds 2 - 500 Minutes 2 - 500 Minutes	
RD1- Rapid Cycle Timer RD2- Restart Delay After All Faults Except Undercurrent (motor cool down timer) RD3- Restart Delay After Undercurrent (dry well recovery timer) #RIL- Number of Restarts After Undercurrent	0, 2 - 500 Seconds 2 - 500 Minutes 2 - 500 Minutes 0, 1, 2, 3, 4, A(Automatic)	
RD1- Rapid Cycle Timer RD2- Restart Delay After All Faults Except Undercurrent (motor cool down timer) RD3- Restart Delay After Undercurrent (dry well recovery timer) #RU- Number of Restarts After Undercurrent ADDR- RS485 Address	0, 2 - 500 Seconds 2 - 500 Minutes 2 - 500 Minutes 0, 1, 2, 3, 4, A(Automatic) A01- A99	
rc- overcurrent rnp Class **     RD1- Rapid Cycle Timer     RD2- Restart Delay After All Faults Except Undercurrent     (motor cool down timer)     RD3- Restart Delay After Undercurrent     (dry well recovery timer)     #RU- Number of Restarts After Undercurrent     ADDR- RS485 Address     #RF-Number of Restarts After All Faults Except Undercurrent***	0, 2 - 500 Seconds 2 - 500 Minutes 2 - 500 Minutes 0, 1, 2, 3, 4, A(Automatic) A01-A99 0, 1, oc1, 2, oc2, 3, oc3, 4, oc4, A, ocA	
rc- overcurrent rinp Class **     RD1- Rapid Cycle Timer     RD2- Restart Delay After All Faults Except Undercurrent     (motor cool down timer)     RD3- Restart Delay After Undercurrent     (dry well recovery timer)     #RU- Number of Restarts After Undercurrent     ADDR- RS485 Address     #RF-Number of Restarts After All Faults Except Undercurrent***     UCTD- Undercurrent Trip Delay	0, 2 - 500 Seconds 2 - 500 Minutes 2 - 500 Minutes 0, 1, 2, 3, 4, A(Automatic) A01- A99 0, 1, oc1, 2, oc2, 3, oc3, 4, oc4, A, ocA 2 - 60 Seconds	
rc- overcurrent rnp Class ***     RD1- Rapid Cycle Timer     RD2- Restart Delay After All Faults Except Undercurrent     (motor cool down timer)     RD3- Restart Delay After Undercurrent     (dry well recovery timer)     #RU- Number of Restarts After Undercurrent     ADDR- RS485 Address     #RF-Number of Restarts After All Faults Except Undercurrent***     UCTD- Undercurrent Trip Delay     GF- Ground Fault Current Threshold	0, 2 - 500 Seconds 2 - 500 Minutes 2 - 500 Minutes 0, 1, 2, 3, 4, A(Automatic) A01-A99 0, 1, oc1, 2, oc2, 3, oc3, 4, oc4, A, ocA 2 - 60 Seconds (3 to 20A) + MULT or 10 to 30% of CT Primary or OFF; LR, (0.3 to 2.0A) + MULT or OFF	
rc- Overcurrent Trip Class **     RD1- Rapid Cycle Timer     RD2- Restart Delay After All Faults Except Undercurrent     (motor cool down timer)     RD3- Restart Delay After Undercurrent     (dry well recovery timer)     #RU- Number of Restarts After Undercurrent     ADDR- RS485 Address     #RF-Number of Restarts After All Faults Except Undercurrent***     UCTD- Undercurrent Trip Delay     GF- Ground Fault Current Threshold	0, 2 - 500 Seconds 2 - 500 Minutes 2 - 500 Minutes 0, 1, 2, 3, 4, A(Automatic) A01-A99 0, 1, oc1, 2, oc2, 3, oc3, 4, oc4, A, ocA 2 - 60 Seconds (3 to 20A) + MULT or 10 to 30% of CT Primary or OFF; LR, (0.3 to 2.0A) + MULT or 00	

SymCom warrants its microcontroller based products against defects in material or workmanship for a period of five (5) years from the date of manufacture. All other products manufactured by SymCom shall be warranted against defects in material and workmanship for a period of two (2) years from the date of manufacture. For complete information on warranty, liability, terms returns, and cancellations, please refer to the SymCom Terms and Conditions of Sale document.

NOTES: SymCom's 777 & 777-LR can be preprogrammed prior to installation by applying 120 VAC between the L1 and L2 terminals \* 575 volt Model (MS 777-575)

\*\* If J prefix is displayed in trip class setting, jam protection is enabled.

\*\*\* If "oc" is disabled in the #RF setting, the overcurrent will be included as a normal fault and the relay will automatically restart after RD2 expires, otherwise, manual reset is required after an overcurrent fault.